

Certificate of Compliance

Certificate: 1176852

Master Contract: 209621

Project: 1176852

Date Issued: April 13, 2001

Issued to: **KLINGER & BORN**
Schlangenäcker 5
D-64395 Brensbach
GERMANY

The products listed below are eligible to bear the CSA Mark shown, with adjacent indicator "C" and "US".



Issued by: G. Foulem, E.I.T.



PRODUCTS

CLASS 3211 04 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Magnetic
CLASS 3211 84 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Magnetic - CERTIFIED TO U.S. STANDARDS

AC-Contactors Type KB-04, open type, 4 pole, operating coil 110-120V ac, 230-240V ac and 460V ac, rated 1 hp 120V ac, 3 hp 240V ac, 5 hp 480V ac, 3ph; 16A 480V ac General Purpose.

Notes:

1. The type designation may be followed by numbers indicating main and auxiliary contacts, and coil voltage.
2. The contactors are Certified as components only for use in equipment where the acceptability of the combination is to be determined by CSA International.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-M91	-	General Requirements - Canadian Electrical Code, Part II
CAN/CSA-C22.2 No. 14-95	-	Industrial Control Equipment
UL Std No. 508	-	Industrial Control Equipment

The "C" and "US" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S. This includes products eligible to bear the NRTL indicator. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognised to perform certification to U.S. Standards.